

CERTIFICATE OF COMPLIANCE

Certificate Number 20190909-R39842
Report Reference R39842-20190828
Issue Date 2019-SEPTEMBER-09

Issued to: FireSafe Pet Doors LLC
89 Center Road
Petaluma CA 94952

**This certificate confirms that
representative samples of**

SPECIAL-PURPOSE FIRE DOORS
Models LG6- LG4, MD6-MD4, and SM6–SM4 are vertical
sliding special purpose type fire door and frame assembly
intended for 20 min no hose locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10C, Positive Pressure Fire Tests of Door
Assemblies;
ANSI/UL 10B, Fire Tests of Door Assemblies

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

